



VÝZKUMNÝ ÚSTAV POZEMNÍCH STAVEB - CERTIFIKAČNÍ SPOLEČNOST, s.r.o.

# CERTIFICATE

## No. OV - 17 - 001

confirms that product

### Plastic drain gutter with stainless steel grate

(ART. SZE 1750)

producer:

**Plast Brno, spol. s r.o.**

Jarní 934/ 32, 61400 Brno, Czech republic

has the following properties:

Technical characteristics	Measurement unit	Measured value	Processes of determination (testing methods)
Appearance	--	inner and outer surface smooth, no defects	ČSN EN 1253-2:2016, cl. 4.1.2
Height of trap	mm	39,5	-
Dimensions of holes in inlet grid	mm	7 x 7	ČSN EN 1253-2:2016, cl. 5.1
Protection against plugging	--	conforms	ČSN EN 1253-1:2016, cl. 5.4
Tightness against odors	--	conforms	ČSN EN 1253-1:2016, cl. 5.8.1
Water tightness	--	conforms	ČSN EN 1253-1:2016, cl. 5.8.2
Flow rate of inlet grate	l/s	0,52	ČSN EN 1253-2:2016, cl. 5.5.1

**This certificate is issued on the basis of following document:**

test report no. A 130/2014 AZL VÚPS - CS s.r.o., dated July 30, 2014 for plastic drain gutter with stainless steel grate

Date of issue: 2.2.2017

Valid until: 2.2.2019

Výzkumný ústav pozemních staveb  
Certifikační společnost, s.r.o.  
102 21 Praha 10 Hostivař, Pražská 10/816  
IČ 250 520 63

*r. a. Lubomír*  
**Ing. Lubomír Keim, CSc.**

director of company

Copy: 1  
K: 17033

Výzkumný ústav pozemních staveb - Certifikační společnost, s.r.o. 102 21 Praha 10 - Hostivař, Pražská 810 / 16  
IČ: 25052063 DIČ: CZ250 520 63 Tel.: 00420 271 751 148, Fax: 00420 281 017 241; E-mail: info@vups.cz www.vups.cz